



## CHAPTER 4

### Compressed Air Distribution (Systems)

**Table 4.11** Discharge of Air through an Orifice

Gage Pressure before Orifice, psi	Nominal Diameter, In.										
	1/64	1/32	1/16	1/8	1/4	3/8	1/2	5/8	3/4	7/8	1
	Discharge, Cu. ft. Free Air Per Min.										
1	.028	0.112	0.450	1.80	7.18	16.2	28.7	45.0	64.7	88.1	115
2	.040	0.158	0.633	2.53	10.1	22.8	40.5	63.3	91.2	124	162
3	.048	0.194	0.775	3.10	12.4	27.8	49.5	77.5	111	152	198
4	.056	0.223	0.892	3.56	14.3	32.1	57.0	89.2	128	175	228
5	.062	0.248	0.993	3.97	15.9	35.7	63.5	99.3	143	195	254
6	.068	0.272	1.09	4.34	17.4	39.1	69.5	109	156	213	278
7	.073	0.293	1.17	4.68	18.7	42.2	75.0	117	168	230	300
9	.083	0.331	1.32	5.30	21.1	47.7	84.7	132	191	260	339
12	.095	0.379	1.52	6.07	24.3	54.6	97.0	152	218	297	388
15	.105	0.420	1.68	6.72	26.9	60.5	108	168	242	329	430
20	.123	0.491	1.96	7.86	31.4	70.7	126	196	283	385	503
25	.140	0.562	2.25	8.98	35.9	80.9	144	225	323	440	575
30	.158	0.633	2.53	10.1	40.5	91.1	162	253	365	496	648
35	.176	0.703	2.81	11.3	45.0	101	180	281	405	551	720
40	.194	0.774	3.10	12.4	49.6	112	198	310	446	607	793
45	.211	0.845	3.38	13.5	54.1	122	216	338	487	662	865
50	.229	0.916	3.66	14.7	58.6	132	235	366	528	718	938
60	.264	1.06	4.23	16.9	67.6	152	271	423	609	828	1,082
70	.300	1.20	4.79	19.2	76.7	173	307	479	690	939	1,227
80	.335	1.34	5.36	21.4	85.7	193	343	536	771	1,050	1,371
90	.370	1.48	5.92	23.7	94.8	213	379	592	853	1,161	1,516
100	.406	1.62	6.49	26.0	104	234	415	649	934	1,272	1,661
110	.441	1.76	7.05	28.2	113	254	452	705	1,016	1,383	1,806
120	.476	1.91	7.62	30.5	122	274	488	762	1,097	1,494	1,951
125	.494	1.98	7.90	31.6	126	284	506	790	1,138	1,549	2,023

Based on 100% coefficient of flow. For well-rounded entrance multiply values by 0.97. For sharp-edged orifices a multiplier of 0.65 may be used.

This table will give approximate results only. For accurate measurements see ASME Power Test Code, Velocity Volume Flow Measurement.

Values for pressures from 1 to 15 psig calculated by standard adiabatic formula.

Values for pressures above 15 psig calculated by approximate formula proposed by S. A. Moss:  $w = 0.5303 a C P_1 \sqrt{T_1}$  where  $w$  = discharge in lb per sec,  $a$  = area of orifice in sq. in.,  $C$  = coefficient of flow,  $P_1$  = upstream total pressure in psia, and  $T_1$  = upstream temperature in deg F abs.

Values used in calculating above table were  $C = 1.0$ ,  $P_1$  = gage pressure + 14.7 psi,  $T_1 = 530$  F abs.

Weights ( $w$ ) were converted to volumes using density factor of 0.07494 lb. per cu. ft. This is correct for dry air at 14.7 psia and 70°F.

Formula cannot be used where  $P_1$  is less than two times the barometric pressure.